GENERAL NOTES

GENERAL NULLS


EAPACTY: DOD GALLONS
TYPE: 1 300 DOUBLE WALL ACT-100-U, UNDERGROUND
NO. REQ.:
WATERIA: MILD CARBON STEEL
TEST: 5 P.S.I.
WIN. GAIDE DR THICKNESS:
(BABED ON 60" MAX. BURIAL BEPTH)
NIMER HADS: 7 GA. OUTER HADS: 10 GA.
NIMER SHELL: 7 GA. OUTER SHELL: 10 GA.
PAINT:
INTERIOR: NONE
EXTERIOR: SP-6 BLAST, COAT WITH 70 MLB OF
POLYMETHANE.
CONSTRUCTION: FLAT FLANCED HEADS, LAP WELD ALL
EXTERIORS: SR, ACT-100-U, H.T. STICKER
- 15000 VOLT SPARK TEST PROMOBED AT FACTORY

124 12* 12" OUTER TANK INNER TANK STRIKER PLATES TYP. 51-51

C.L. TANK

FITTING SCHEDULE

A= 3" # NPT WITH 3" x 2" NYLON BUSHING B= 5" # NPT WITH 5" x 4" NYLON BUSHING G= 3" # NPT WITH 3" x 2" NYLON BUSHING (FITTING FOR LEAK DETECTION W) INTERNAL PIPE)



NOTE: ALL ROHTS RESERVED. THIS DRAWING OR ANY PART THEREOF NUST NOT BE REPRODUEDD IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF HIGH-AND TANK.
HIBHLAND TANK SHALL BE RESPONSELE ONLY FOR ITEMS NOICATED ON THIS RABICATION DRAWING UNLESS OF HERWISE NOTED. CLISTOMER IS RESPONSELE FOR VERRYING CORRECTEDS OF 50ZE / LIDCHITON OF THIS RESPONSELE FOR VERRYING CORRECTEDS OF 50ZE / LIDCHITON OF THIS RESPONSELE FOR VERRYING CORRECTEDS OF 50ZE / LIDCHITON OF THIS RESPONSELE FOR VERRYING CORRECTEDS OF 50ZE / LIDCHITON OF THIS RESPONSELE FOR VERRYING SHOWN DO THIS DRAWING

NOTE: POLYMETHANE ACT-100-U TANK IS NOT APPROVED FOR THE STORAGE OF HEATER PRODUCTS NOTE: TANK HAS 30 YEAR LIMITED WARRANTY THROUGH STEEL TANK INSURANCE COMPANY

END VIEW

ELEVATION

ALL RIGHTS RESERVED. THIS DRAWING OR ANY PART THEREOF MUST NOT BE RE-PRODUCED IN ANY FORM WITHOUT WRITTEN PERMISSION OF AREA-POWER UNITZED FUELER, INC.

DUE NOOD DIE ALGOU T

7

DATE

REV

103 SMITHTOWN BLVD SMITHTOWN, NY 11787

ACT-100U 500 GAL U/G TYPE 1 D/W

DRAWING TITLE

THE MESON TIME	AIVOU /
5CALE: 1/2"=1'	DWN BY: HT
SHEET: 1	DATE: 11 /1 /02